



# LOS ANGELES FIRE DEPARTMENT FILM LOCATION FIRE SAFETY INSPECTION CHECKLIST



PERMIT NUMBER _____	DATES OF FILMING _____
LOCATION ADDRESS _____	PRODUCTION NAME _____

THIS CHECKLIST MUST BE COMPLETED DAILY FOR EACH PERMITTED FILMING LOCATION AND MUST BE AVAILABLE WITH A COPY OF THE FILM PERMIT. This checklist shall be provided to any Los Angeles Fire Department Inspector visiting the filming location.

For each item below, indicate if the location matches the statement or if it is Not Applicable. For each NO answer, corrective actions must be noted and executed before filming can continue. Please consult the attached explanation of each line item.

	Date:			Date:			Date:		
	Y	N	N/A	Y	N	N/A	Y	N	N/A
<b>I. ACCESS</b>									
A. Fire truck access must be maintained (20 feet wide).....	—	—	—	—	—	—	—	—	—
B. Fire hydrants, extinguishers, sprinklers & standpipe connections clear of all equipment & vehicles.....	—	—	—	—	—	—	—	—	—
CORRECTIVE ACTION TO BE TAKEN: _____									
_____									
<b>II. EXITING</b>									
A. All designated fire, emergency and regular exits must be clear (i.e., 4 ft. perimeter around set).....	—	—	—	—	—	—	—	—	—
B. All exits must be adequate, visible, lit and well marked.....	—	—	—	—	—	—	—	—	—
C. All exits must be clear of hazards (combustible materials, flammable liquids, LPG and pyrotechnics).....	—	—	—	—	—	—	—	—	—
CORRECTIVE ACTION TO BE TAKEN: _____									
_____									
<b>III. FLAMMABLE LIQUIDS &amp; GASES</b>									
A. Proper storage of flammable liquids in approved containers (max. 5 gallon containers).....	—	—	—	—	—	—	—	—	—
B. Propane and other pressure vessels secured and stored outside with "No Smoking" signs and protected from vehicle traffic.....	—	—	—	—	—	—	—	—	—
C. Approved hoses and valves for pressurized gases.....	—	—	—	—	—	—	—	—	—
D. Flammable liquids and gases kept 25 feet away from heat sources.....	—	—	—	—	—	—	—	—	—
E. No refueling of generators or other equipment while in operation.....	—	—	—	—	—	—	—	—	—
F. Refueling done in approved area.....	—	—	—	—	—	—	—	—	—
G. Refueler vehicle must possess a valid Div. 5 permit.....	—	—	—	—	—	—	—	—	—
H. Supply and receiving vessels bonded together.....	—	—	—	—	—	—	—	—	—
I. Spray painting and lacquer application approved and performed safely.....	—	—	—	—	—	—	—	—	—
J. Proper ventilation to prevent flammable vapors from accumulating.....	—	—	—	—	—	—	—	—	—
CORRECTIVE ACTION TO BE TAKEN: _____									
_____									



	Date:			Date:			Date:		
	Y	N	N/A	Y	N	N/A	Y	N	N/A
<b>VII. PYROTECHNIC SPECIAL EFFECTS</b>									
A. Proper license in possession of pyrotechnician.....	—	—	—	—	—	—	—	—	—
B. LAFD Special Permit on site.....	—	—	—	—	—	—	—	—	—
C. A safety meeting shall be conducted prior to pyrotechnic activity.....	—	—	—	—	—	—	—	—	—
D. Fire extinguisher provided by pyrotechnician.....	—	—	—	—	—	—	—	—	—
E. Fire extinguisher charged and in good working order.....	—	—	—	—	—	—	—	—	—
F. Special effects used as per LAFD Special Permit.....	—	—	—	—	—	—	—	—	—
CORRECTIVE ACTION TO BE TAKEN: _____									
_____									
<b>VIII. HIGH RISE BUILDINGS</b>									
A. Fire alarm equipment shall not be disconnected without Fire Dept. approval.....	—	—	—	—	—	—	—	—	—
B. All fire rated doors (hallways, stairway, etc.) shall be kept clear of cables, equipment, etc.....	—	—	—	—	—	—	—	—	—
C. All hallways and stairways shall be kept clear and unobstructed.....	—	—	—	—	—	—	—	—	—
D. Fire escapes cannot be used for storage or operational activity, and must be kept clear as escape routes.....	—	—	—	—	—	—	—	—	—
CORRECTIVE ACTION TO BE TAKEN: _____									
_____									

Should LAFD Inspectors need further information regarding the completion of this form, please contact:

\_\_\_\_\_  
Date

\_\_\_\_\_  
Name                      Title                      Phone Number                      Name                      Title                      Phone Number

\_\_\_\_\_  
LAFD Inspector Signature

\_\_\_\_\_  
Date

\_\_\_\_\_  
Name                      Title                      Phone Number                      Name                      Title                      Phone Number

\_\_\_\_\_  
LAFD Inspector Signature

\_\_\_\_\_  
Date

\_\_\_\_\_  
Name                      Title                      Phone Number                      Name                      Title                      Phone Number

\_\_\_\_\_  
LAFD Inspector Signature